

2016 System Performance Annual Report

(Submitted as required by the NC General Assembly House Bill 1160 Clean Water Act of 1999.)

Reporting Period: **January 1, 2016 to December 30, 2016**

I. General Information

- Name of regulated entity: **Town of Banner Elk WWTP**
- Responsible person: **Rick Owen**
 - mailing address: **PO Box 2049; Banner Elk, NC 28604-2049**
 - phone number: **828-898-5398**
 - facility located at: **Mill Pond Road**
 - county: **Avery**
 - DWQ Regional Office: **Asheville**
- Listing of applicable permit(s): **NC0032115**
- Description of collection system and wastewater treatment system or process:

Deemed permitted Collection System consists of:

Consists of 12 miles of gravity lines and 0.25 miles of force mains with one lift station.

NC0032115 Wastewater Treatment Facilities

0.600 MGD extended aeration WWTP plant consisting of: bar screen; comminutor; grit removal chamber; 40,000 gal flow equalization basin with fine bubble diffusers and dual 260 gpm submersible pumps; flow splitter box; dual 100,000 aeration basins with fine bubble diffusers and blower capacity of 900 cfm providing diffused air; 34 ft dia x 14 ft deep circular clarifier with sludge return; sludge pump station with dual 245 gpm pumps; 118,000 gal aerobic digester with dual 50 HP blowers; UV disinfection; 0.8 meter belt filter press capable of treating 325 lbs dry solids per hour; covered sludge drying beds and 85 ft x 55 ft sludge storage pad; flow measuring device with totalizer; and emergency stand-by power.

II. System Performance Annual Summary:

- A. Description of overall 12 month performance, noting highlights and deficiencies: **The treatment plant did very well last year.** In January the plant was not seen for one day due to snow.
- B. By month, list of the number and type of any violations of permit conditions, environmental regulations or environmental laws, including (but not limited to):

1. Permit Limit Violations (NOVs and Civil Assessments):

NONE

2. Monitoring and Reporting Violations (NOVs and Civil Assessments)
(Illegal) Bypass of treatment facilities*

January plant not seen for one day due to snow

3. Sanitary Sewer Overflows* (NOVs and Civil Assessments)

***Note estimated total monthly volumes and locations of events in which more than 1,000 gallons of waste reached surface waters.**

NONE

C. Description of any known environmental impact of violations:

NONE

D. Description of corrective measures taken to address violations or deficiencies

NONE

III. Notification

Statement as to how users or customers have been provided access to the report.

This annual report has been sent to the North Carolina Division of Water Quality and to the owner of the wastewater system. The wastewater system owner has also been given a letter that they can easily distribute to all their customers. The letter will inform the customers that the annual report is available upon request to the owner of the system.

IV. Certification

A. Certified Operator in Responsible Charge:

ORC:	Jadd Brewer	Cert. # 10206 – WW III
Back-up ORCs:	Denver Eggers	Cert. # 10541 – WW II
	Paul Isenhour	Cert. # 13154 – WW IV
	Jerry Alexander	Cert. # 989701 – WW IV

B. Statement by a responsible official certifying the report is accurate and complete:

I, Jadd Brewer, certify that this report is accurate and complete, to the best of my knowledge.

C. Signature of responsible official and date of report:

Jadd Brewer

date